



Precision Polymer Engineering Limited  
Greenbank Business Park  
Greenbank Road  
Blackburn  
BB1 3EA  
Telephone: +44 (0) 1254 295400  
Fax: +44 (0) 1254 680182

Reference: Water-WRAS/S70C  
Date: 30<sup>th</sup> January 2023

## --- Certificate ---

### **S70C – Silicone Rubber – 5410** **For cold and hot water use (up to 85°C)**

**Water Regulations Advisory Scheme (WRAS)**  
Items which have passed full tests of effect on water quality – BS 6920

This is to certify that the material described above is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

This material is suitable for use in contact with potable water in cold and hot water applications up to 85°C, as O-rings between 1.78mm and 7.00mm cross section. Approval of this material does not signify the approval of its mechanical or physical properties for any use.

This product automatically becomes due for audit reassessment in November 2027.

Approval number: 2211558. Test Report: J-00431665 & J-00431666

A handwritten signature in black ink that reads 'Stefano Arrigoni'.



Stefano Arrigoni  
Head of Research and Development  
IDEX Sealing Solutions