



Precision Polymer Engineering Limited
Greenbank Business Park
Greenbank Road
Blackburn
BB1 3EA
Telephone: +44 (0) 1254 295400
Fax: +44 (0) 1254 680182

Reference: Water-WRAS/S71U
Date: 22nd July 2020

--- Certificate ---

S71U – Platinum-cured Silicone Rubber – 5410
For cold and hot water use (up to 85°C)

Water Regulations Advisory Scheme (WRAS)
Items which have passed full tests of effect on water quality – BS 6920

This is to certify that the material described above is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 *'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'*.

This material is suitable for use in contact with potable water in cold and hot water applications up to 85°C, as O-rings between 1.78mm and 5.70mm cross section. Approval of this material does not signify the approval of its mechanical or physical properties for any use.

This product automatically becomes due for audit reassessment in July 2025.

Approval number: 2007505. Test Report: MA6887/Q.



Stefano Arrigoni
Head of Research and Development
IDEX Sealing Solutions